

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Qingdao TGOOD Electric Co., Ltd.

Qingdao, China

has successfully passed the type test sequence on a three-pole
air-insulated

earthing switch

Type: JN15-12/31.5-210

Rating: 17,5 kV – 31,5 kA – 82 kA_{peak} – 50/60 Hz

The test object passed the specification of test duties of

IEC 62271-102

The test results are recorded in Certificate No.

2324-15

This Certificate was issued on 28 January 2016.

KEMA Nederland B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories



KEMA

Laboratories

© DNV GL

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that DNV GL has certified or approved any object other than the specimen tested.