

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Qingdao TGOOD Electric Co., Ltd.

Qingdao, China

has successfully passed the type test sequence on a three-pole
air-insulated

earthing switch

Type: JN15-12/31,5-275

Rating: 17,5 kV – 31,5 kA – 82 kA_{peak} – 50/60 Hz

The test object passed the specification of test duties of

IEC 62271-102

The test results are recorded in Certificate No.

2329-15

This Certificate was issued on 28 January 2016.

KEMA Nederland B.V.

J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA

Laboratories

