

# KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

## **Qingdao TGOOD Electric Co., Ltd.**

Qingdao, China

has successfully passed the type test sequence on a three-pole  
air-insulated

### **metal-enclosed switchgear assembly**

Type: TAP 17-31-31

Rating: 17,5 kV – 3150 A (1) – 31,5 kA – 50/60 Hz

(1) Temperature-rise test performed at 3000 A (60 Hz) and at 3150 A (50 Hz).

The test object passed the specification of test duties of

### **IEC 62271-200**

The test results are recorded in Certificate No.

**2326-15**

This Certificate was issued on 28 January 2016.

KEMA Nederland B.V.



J.P. Fonteijne  
Executive Vice President  
KEMA Laboratories



**KEMA** Laboratories

© DNV GL

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that DNV GL has certified or approved any object other than the specimen tested.