

KEMA TYPE TEST CERTIFICATE OF SHORT-CIRCUIT PERFORMANCE

Qingdao TGOOD Electric Co., Ltd.

Qingdao, China

has successfully passed the type test sequence on a three-pole
withdrawable air-insulated

vacuum circuit-breaker

Type: TCB 17-31-12

Rating: 17,5 kV – 1250 A – 31,5 kA – 60 Hz

The test object passed the specification of test duties of

IEEE Std C37.09 and IEEE Std C37.09b

(Table 1: STC, T10, T30, T60, T100s, T100a, T100s 1Ph, T100a 1Ph)

The test results are recorded in Certificate No.

2325-15

This Certificate was issued on 28 January 2016.

KEMA Nederland B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories



KEMA

Laboratories

© DNV GL

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that DNV GL has certified or approved any object other than the specimen tested.