

KEMA TYPE TEST CERTIFICATE OF SWITCHING PERFORMANCE

Qingdao TGOOD Electric Co., Ltd.

Qingdao, China

has successfully passed the type test sequence on a three-pole

GIS SF₆ circuit-breaker

Type: TGP 145-40-31

Rating: 145 kV – 3150 A – 40 kA – 50/60 Hz (1)

(1) Tests performed at 60 Hz.

The test object passed the specification of test duties of

IEC 62271-100

subclauses 6.102 and 6.111 (Capacitive current).

The test results are recorded in Certificate No.

2417-15

This Certificate was issued on 29 January 2016.

KEMA Nederland B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA Laboratories

